

\$aaS0

Description:

Command to perform internal calibration on the device.

Command Syntax:

\$aaS0[CS](CR)	
\$	Delimiter character
aa	Address of the device to be calibrated
S0	Command to perform internal calibration
[CS]	Checksum
(CR)	Carriage Return

Response:

Valid Command: **!aa[CS](CR)**

Invalid Command: **?aa[CS](CR)**

!	Delimiter for a valid command
?	Delimiter for an invalid command
aa	Address of the responding device
[CS]	Checksum
(CR)	Carriage Return

Examples:

Send a command to perform internal calibration of the device and valid response is returned.

Command: \$01S0(CR)

Response: !01(CR)

Note: There is no response from the device in three circumstances. If the command syntax is incorrect, there is a communication error or if no device with the address in the command can be found.