

#aan(Data)

Applies to: ED-560

Description:

Command to set the output value of channel n.

Command Syntax:

~ aa3n[CS] (CR)	
#	Delimiter character
aa	Address of the device to be configured, in hexadecimal format (00 to FF)
n	The channel to be read (0 to F)
(Value)	The value for channel n to be set to
[CS]	Checksum
(CR)	Carriage Return

Response:

Valid Command: >**[CS]**(CR)

Invalid Command: ?**aa[CS]**(CR)

>	Delimiter for a valid command
?	Delimiter for an invalid command
[CS]	Checksum
(CR)	Carriage Return